

SYED NASIM UZ ZAMAN
REGISTERED TECHNICAL PERSON (ENGINEER)
GUWAHATI METROPOLITAN DEVELOPMENT AUTHORITY
House No. 8, Sivanath Gogoi Path, 1st By-lane, Panjabari, Guwahati 781037
Assam
E-Mail: zamansn@gmail.com
Mobile: 9707011778

Date: 12/07/2023


TO WHOM IT MAY CONCERN

The undersigned RTP inspected GUWAHATI PUBLIC SCHOOL, PANJABARI, GUWAHATI 781037 on **10.07.2023** and is pleased to state the following.

1. The measurement of the old building: 1710.03 square meters in the ground floor with R.C.C. ceiling and the First Floor of the area 1710.03 square meters completed with G.C.I Sheet Roof on tubular truss.
2. The measurement of the new building: 1742.56 square meters in the ground floor R.C.C ceiling and 1742.56 square of First Floor of Area with R.C.C roof.
3. A stage for cultural activities measuring 21.16 square meters (4.6mX4.6m) with a height of 1.0 (one) meter from the ground level completed with PCC flooring and G.C.I Sheet Roof on tubular truss as an extension with the old building.

All the buildings were observed without any cracks and seem to be structurally safe. No settlement was observed and the maintenance of the building has been carried out as per requirement. From the observation it seems that the construction of the school building was carried out following the building bylaws of the time. The constructions school buildings were done in 1992 and 1995 respectively. The buildings encountered several earthquakes of various intensities without any damage.

The foundation and the superstructure school buildings should remain structurally safe for institutional purposes for 10 (ten) years from the date of inspection.


Syed Nasimuz Zaman
GMDA/RTP/2015/ENG-10/02

SYED NASIM UZ ZAMAN
GMDA/RTP/2015/ENG-10/02