

M.D. Enterprise

Deals in : All Types of Fire Extinguisher, Fire Detector, Fire Alarm, Hydrant System, Sprinkler, Electrical & Electronic, Maintenance Security Systems, CCTV & General Order Supplier

Guwahati College Road, Ganeshnagar, Near L.P. School, H.No.-150, Bamunimaidam, Guwahati- 781021

Ph.: 9101042846 (M)

Email: mdenterprise894@gmail.com

Ref. No. :

Date :

TEST CERTIFICATE

This is to Certify that we have tested the following fire Extinguisher hydraulic pressure test.

Sl No	Type of Fire Extinguisher	Qty	Cylinder No	Tested to	Remarks
01.	ABC Stored Pressure type 5kg	02Nos	Old	35kg/cm2	Ok
02.	(BC) Dry Chemical Powder 5kg	02Nos	Old	25kg/cm2	Ok
03.	ABC stored Pressure type 2kg	20Nos	Old	35kg/cm2	Ok

1. Name of the Party : Guwahati Public School, panjaberi, Guwahati.

2. Quantity of fire extinguisher : 24Nos.

3. Date of Hydraulic Test : 20-02-2023.

4. Date of Servicing / Refilling : 20-02-2023.

5. Due date of refilling : 19-02-2024.

6. Period of Guarantee : One year (Date of Install)

For Authorized signaure

