

M.D. Enterprise

Deals in : All Types of Fire Extinguisher, Fire Detector, Fire Alarm, Hydrant System, Sprinkler, Electrical & Electronic, Maintenance Security Systems, CCTV & General Order Supplier

Ph.: 9101042846 (M)
Email: mdenterprise894@gmail.com

Guwahati College Road, Ganeshnagar, Near L.P. School, H.No.-150, Bamunimaidam, Guwahati- 781021

Ref. No. : MD/E/2023-24/6094

Date : 20/02/2023

TEST AND WARRANTY CERTIFICATE

This is to certify that we have tested the following fire extinguisher hydraulic pressure test.

SL No	Type of Fire Extinguisher	Qty	Cylinder No	Tested to	Remarks
01.	ABC Stored Pressure type 5kg Fire Extinguisher.	02Nos	Old	35kg/cm ²	Ok
02.	(BC) Dry Chemical Powder 5kg Fire Extinguisher.	02Nos	Old	25kg/cm ²	Ok
03.	ABC stored Pressure type 2kg Fire Extinguisher.	20Nos	Old	35kg/cm ²	Ok

1.Name of the Party: Guwahati Public School., Panjabari, Guwahati.

2.Quantity of Fire Extinguisher : 24Nos

3.Date of Hydraulic Test : 20-02-2023.

4.Date of Servicing / Refilling : 20-02--2023.

5.Due Date of Refilling : 19 -02-2024.

6.Period of Guarantee : One Year (Date of Refill.)

For Authorized Signature

